



liftinstituut
SINCE 1933



EU-TYPE EXAMINATION CERTIFICATE

Issued by Liftinstituut B.V.
identification number Notified Body 0400

Certificate no.	: NL07-400-1002-034-04	Revision no.:	3
Description of the product	: Door locking device for swing doors		
Trademark	: CAN-LIFT		
Type no.	: CL01-M and CL01-MD		
Name and address of the manufacturer	: CAN-LIFT Asansör San. Ve. Tic.Ltd.Şti İnönü Mah. Balçık Köyü Yolu Üzeri GEPOSB İç 7. Cad. No.6, 41400 Gebze – Kocaeli / Türkiye		
Name and address of the certificate holder	: CAN-LIFT Asansör San. Ve. Tic.Ltd.Şti İnönü Mah. Balçık Köyü Yolu Üzeri GEPOSB İç 7. Cad. No.6, 41400 Gebze – Kocaeli / Türkiye		
Certificate issued on the following requirements	: Lifts Directive 2014/33/EU		
Certificate based on the following standard	: EN81-20:2020, EN81-50:2020 (EN81-1/2:1998)		
Test laboratory	: None		
Date and number of the laboratory report	: None		
Date of EU-type examination	: 2026-04-20		
Additional document with this certificate	: Report belonging to the EU-type examination certificate no.: NL07-400-1002-034-04 rev.3		
Additional remarks	: - This revision replaces certificate NL07-400-1002-034-04 rev.2 of 2021-02-16. - The door lock shall be used for swing doors only Max. rated voltage 230 VAC Max. rated current 0,5 A Max. door gap 8 mm See chapter 5 of the report belonging to this EU-type examination certificate for additional conditions.		



liftinstituut
SINCE 1933



Conclusion

: The safety component meets the requirements of the Lifts Directive 2014/33/EU considering any additional remarks mentioned above

Amsterdam

Date : 2026-04-22

Valid until : 2031-04-22

Authorised by

W.G. Kasteleijn

Product Manager Certification